



January 30, 2024

Dear Parents and Guardians,

We are writing to let you know that Sunapee Central Elementary School recently completed testing for lead in drinking water. This is part of an ongoing effort related to New Hampshire's House Bill 1421, which requires school and childcare facilities to test for lead in drinking water and to act when lead is found at levels at or above 5 parts per billion (ppb).

Lead is a toxic heavy metal that has a range of adverse health effects if inhaled or swallowed. Lead rarely occurs naturally in New Hampshire's drinking water sources (groundwater or surface water). It typically enters drinking water due to the wearing away of piping, faucets, fixtures, and other plumbing materials.

Because lead is tasteless, odorless, and colorless in drinking water, testing is the only way to learn whether lead is present. It is important to sample each faucet or water fountain used for drinking or food prep because test results can vary between locations.

During recent testing, we collected samples from 12 drinking water outlets (e.g., drinking fountains, classroom faucets, kitchen sinks), with 4 samples testing at or above 5 ppb, the level where action must be taken.

We have removed access to these outlets until the problem can be corrected. The chart below shows a list of all of the tested outlets, their locations, sample results, and our planned remediation. If the result column shows 'BRL' (below reporting limit), no lead was detected above the laboratory's reporting limit.

R122005-2- Hallway WF	Drinking Fountain	BRL
R122005-3-Teacher's Room	Kitchen Faucet	18
R122005-4-Hallway	Drinking Fountain	BRL
R122005-5-Kitchen (Near Window)	Kitchen Faucet	5.3
R122005-6-Middle Station	Kitchen Faucet	1.6
R122005-7- Hand Washing Sink	Kitchen Faucet	1.7
R122005-8- Outside 1103	Drinking Fountain	BRL
R122005-9- Room 1103	Kitchen Faucet	110
R122005-10-Water Fountain Near Office	Drinking Fountain	BRL
R122005-11- Gym Entrance Fountain	Drinking Fountain	BRL
R122005-12- Gym Teacher Room 12	Bathroom Faucet	3.6
R122005-13- Sink In Coaches Office	Bathroom Faucet	10

All sample results and additional resources from the New Hampshire Department of Environmental Services (NHDES) can be viewed at [gettheleadoutnh.org](https://www.gettheleadoutnh.org).

Sincerely,

Russell E Holden

Superintendent of Schools